



Hong Kong Industrial Safety Association

Firestop Applications for Fire Safety in Buildings 2012

Speaker: Mr. Ricky Tsang, Design Engineer, Hilti (HK) Ltd

Agenda (1.5hr)

- ❖ **Introduction**

- ❖ **Passive Fire Protection Overview**
- ❖ **The new FS COP 2011**
- ❖ **Firestop Designs and Applications**
- ❖ **Additional Tests for Firestop Products**
- ❖ **Open Discussion**

What's the COST of a fire ?

Worldwide, at 2010, a fire breaks out **every 23 sec:**

- **1.33 million** fires incidents
- **31,20** deaths, **17,720** injuries in fires
- **Direct Property losses \$11.6 billion**

Harbour Plaza HK – Apr 20



Fa Yuen Street – Nov 2011



Ordnance Court, Hong Kong – Aug 20



Who suffer ? Definitely the property owner. More importantly, life is invaluable.

Source: Apple Daily

Windsor Tower: Madrid, Spain



Introduction

SMOKE is the major Killer

- Smoke travels at between 50 and 100m per minute
- 67% of fire related deaths are through smoke inhalation
- 44% of deaths are people who were not in the room of origin
- 47% of survivors could not see more than 4 m



Flash-over Time

Home Fire

<http://www.youtube.com/watch?v=QgMVm72FMRk&feature=related>

Office Fire

<http://www.youtube.com/watch?v=G6ILbDQcJyA&feature=related>

A Fire Accident

<http://www.youtube.com/watch?v=10SuXWMOQlo>

4 Levels of Life Safety

Prevention




Training,
Fire Exercises, ...

Detection



Fire Alarms

Active
Fire Protection



Sprinkler Systems,
Extinguishers

Passive
Fire Protection




Fire Doors,
Fire-rated Walls / Floors,
Firestop Systems

Fire Compartments

Every Buildings should be divided into fire compartment not exceeding the size stipulated in **Code of Practice for Fire Safety in Buildings 2011 (Table C1)**


For Example: Compartment for Commercial Business Facilities should $< 10,500\text{m}^2$

Fire walls



FW = Fire walls


Fire floors




FF = Fire floors

Weak Points in Buildings

- 1 Unsealed / Open Joints
- 2 Unsealed Cable Penetrations
- 3 Unsealed Pipe Penetrations / Ducts
- 4 Doors / Windows
- 5 Curtain Wall Joints



Firestop applications survey



Regulations

Regulations depend on the size and type of construction:




Residential



Commercial




Industrial



Regulations are more stringent for commercial and industrial buildings.

Weak Points in Buildings (Example)



Risk:
Unsealed pipe penetration




Result:
Ash & rubble
↓
(Damage & Loss)

Test Measurement (F.R.R Fire Resistance Rating)


Fire resistance is measured with the following factors:

1




Load bearing Capacity:
 Measures the structural stability of an element in case of a fire

2



Integrity (F-Rating)
 Measures the ability of an element to prevent gas and flame to pass through in case of a fire

3




Insulation (T-Rating)
 Measures the ability of an element to insulate, i.e. how long it takes for the non-fire side of the element to reach 180° C/325° F plus ambient temperature

All three criteria are measured in hours and minutes.


Fire Test

- Firestop products are tested under severe fire conditions according to a world-wide standard ISO-temperature curve

Phases of a fire in practice




Phases of a fire when testing



- Each country may require additional test conditions.
Examples: Furnace pressure, thermo couple position, hose stream test,


The Code of Practice for Fire Safety in Building 2011



The FS Code comprises 7 parts and 1 annex:

- Part A Introduction
- Part B Means of Escape
- Part C Fire Resisting Construction**
- Part D Means Of Access
- Part E Fire Properties of Building Elements and Components
- Part F Fire Safety Management
- Part G Guidelines on Fire Engineering
- Annex A List of Codes of Practice and Guides issued by Licensing Authorities for Licensed Premises

The Code of Practice for Fire Safty in Building 2011



Application of the New Fire Code 2011 has come into operation on **1.Apr.2012** except:

- For buildings or buildings work which are being carried out or consent to the commencement of which has been given on or before 1.Apr.2012, the MOE code, the FRC code and the MOA Code may continue to be applicable. Consent refers to that of foundation works of such buildings.

Fire resistance ratings (FRR) are designed by three terms, to represent the make up of the element of construction, i.e. X/Y/Z, where

- X – Stability fire resistance rating (minutes)
- Y – Integrity fire resistance rating (minutes)
- Z – Insulation fire resistance rating (minutes)

Part C Fire Resisting Construction

It includes the requirements on:

- Fire separation between buildings, fire compartments, Use Classification and occupancies
- Protection of required staircases, openings, area of special hazard, basement, refuge floor etc.

Part C Fire Resisting Construction – Subsection C3

Paragraph 5.2 (FRC 1996)

- ~~Compartment walls, compartment floors, separations and lobbies should be constructed such that all joints are completely filled with non-combustible material to prevent the passage of smoke or flame. No compartment should exceed the volume specified in Table 1 below.~~

Clause C3.2 (Fire code 2011)

- A fire compartment should be enclosed by fire barriers. Protection of all openings, joints and penetrations located in a fire barrier should have an **FRR** not less than that of the fire barrier.



Part C Fire Resisting Construction – Subsection C4

- Every Building should be divided into **fire compartment** not exceeding the size stipulated in Table C1 (in term of area)
- Every element of construction and fire barrier should have an **FRR** not less than the specifies in Table C1
- All openings, joints and penetrations should be protected by materials with **FRR** not less than that of the fire barriers

Use Classification	Compartment Area/ Volume	Fire Resistance Rating (minutes)
4. Commercial:		
4a. Business Facilities	Not exceeding 10,500m ²	60
4b. Mercantile Facilities	Not exceeding 2,500m ²	60
	Exceeding 2,500m ² but not exceeding 10,500m ²	120
5. Assembly:		
5a & 5d. PPE & Other assembly premises	Not exceeding 2,500m ²	60
	Exceeding 2,500m ² but not exceeding 10,500m ²	120
5b. Educational establishments	Not exceeding 2,500m ²	60
	Exceeding 2,500m ² but not exceeding 10,500m ²	120
5c. Transport facilities	Not exceeding 10,500m ²	120

Table C1

Part C Fire Resisting Construction – Subsection C4

Notes:

2. Different Use Classifications should be separated in accordance with Subsection C7
3. Special hazards should be separated in accordance with Subsection C13
4. For any use not covered by Table C1, the **FRR** required will be determined by the Building Authority having regard to the fire load, hazard level and other relevant fire safety provisions of the building
5. For Use Classification 1 - Residential, **each flat should be separated from adjoining flats by fire barriers**
6. For Use Classification 2 - Hotel, each guestroom should be separated from the adjoining guestrooms and other Use Classifications by fire barriers

Part C Fire Resisting Construction – Subsection C4

Integrity

6	Loadbearing wall being a fire barrier	Y	Y	Y	Each side separately
7	Non-loadbearing wall being a fire barrier	N	Y	Y	Each side separately
8	Protected shaft, lobby and corridor	Y*	Y	Y	Each side separately
9	Fire shutter, fire stop, fire dampers, sealing system	N	Y	N (unless specified)	Each side separately
10	Smoke outlet shaft	Y	Y	Y	From outside
11	Enclosure around services other than Item 14	N	Y	Y	From outside

Table C2

Part C Fire Resisting Construction – Subsection C6

Protection of flats in Use Classifications 1 and 2 (Clause C6.1)

- Common internal corridor should be protected by fire barriers having an FRR that complies with Table C1
- Doors of each flat / guestroom should have an FRR not less than that of the common internal corridor

~~(FRC 1996, FRP of doors not less than ½ of the common internal corridor)~~

- A smoke seal should be installed to each fire rated door



CP 606
Firestop
Sealant

Part C Fire Resisting Construction – Subsection C8

Protection of openings for passing building services

Every opening through a fire barrier should be protected with **firestop to maintain the FRR** of that fire barrier.

The gaps between the water-borne metallic pipes and fire barrier should be filled by fire rated material having an **FRR of not less than** that of the fire barrier.




Part C Fire Resisting Construction – Subsection C8

Protection of openings for passing building services

Clause C8.5

Any Fire sealing system should comply with the following requirements:

- (a) The sealing system should comply with the requirement in Part E
- (b) The performance of the sealing system should not be affected by moisture or dampness
- (c) The life of the sealing system should not be shorter than that of the duct, pipe or wire; and
- (d) The sealing should be firmly fixed



MAKE USE OF OUR AGING TEST REPORT & MANUFACTURER CERTIFICATE

Part C Fire Resisting Construction – much more

Protection of lifts
Protection of Openings between Floors
(Curtain Wall)
Protection against external fire spread
Protection of Areas of Special Hazard
Protection of Basement




Firestop Designs and Applications

Passive fire protection is NOT just firestop sealant...



Design Example



1. CONCRETE FLOOR ASSEMBLY (4-HR F.R.P.).
2. CONCRETE WALL OR FIRE-RATED BLOCK WALL
3. **MINERAL WOOL**
4. **JOINT WIDTH = 90mm**


CP601S Elastic Firestop Sealant

Features:

- Up to 4-hr-FRP
- Up to 25% movement capability

Applications:

- Movement Joints (100mm gap width)
- Metal Water Pipes (40mm gap width)



CP606 Flexible Firestop Sealant


What is ?

Features?

- Up to 4-hr-FRP
- Up to 10% movement capability

Applications:

- Movement Joint (30mm gap width)




Joint Application

CP606 Flexible Firestop Sealant




- Acrylic Based
- Indoor-use
- Paintable
- 10% movement
- Constant 80°C
- Max. 30mm joint



CP601S Elastic Firestop Sealant



- Silicone Based
- Outdoor-use
- Non-paintable
- 25% movement
- Constant 160°C
- Max. 100mm joint




Design Example (Cont')

FIRE RATED PERIOD : 4 HOURS

PRODUCT USED : CP601S ELASTIC FIRESTOP SEALANT

British Standard
BS 476-20




CROSS-SECTIONAL VIEW


1. CONCRETE FLOOR ASSEMBLY (4-HR F.R.P.).
2. CONCRETE WALL OR FIRE-RATED BLOCK WALL (MIN. 150mm THK) (4-HR F.R.P.).
3. MIN. 100kg/m³ DENSITY MINERAL WOOL FULLY FILLED ACROSS AS BACKING.
4. (JOINT WIDTH ≤ 15mm) MIN. 6mm DEPTH **HILTI CP601S ELASTIC FIRESTOP SEALANT**, FLUSH WITH BOTH SIDES OF THE WALL SURFACE.
(JOINT WIDTH ≤ 100mm) MIN. 15mm DEPTH **HILTI CP601S ELASTIC FIRESTOP SEALANT**, FLUSH WITH BOTH SIDES OF THE WALL SURFACE.

Design Example 2

TOP VIEW / SIDE VIEW



SECTION A-A
(FLOOR)



- 1. CONCRETE FLOOR
- ~~A. CONCRETE WALL OR FIRE-RATED BLOCKWALL~~
- B. CONCRETE FLOOR
- 2. METAL CABLE TRAY(S).
- 3. ELECTRIC CABLE(S).
- 4. **OPENING TO BE FILLED (3m x 0.6m)**

CP636 Firestop Mortar

Features:

- Up to 4-hr-FRP
- No shrinkage
- Paintable

Applications:

- Cable Tray
- Lift Door Frame
- Damper
- max opening size
floor 1m x 0.6m x 150mm(T)
wall 1.2 x 2m(H) x 100mm(T)



CP 670 – Fire Safety Board

Quick cut. Perfect fit.


Features:

- Up to 2-hr-FRP
- No shrinkage
- Paintable
- Easy to apply

Applications:

- Cable Tray
- Lift Door Frame
- Damper
- max opening size
floor 1.3x5mx150mm(T)
wall 2.4x5mx100mm(T)

Quick cut. Perfect fit.
Piece of mind.




Hilti CP 670 Fire Safety Board System

Firestop safety board with an elastic, non-stick skin. No more crumbling, no more delamination. Just tested, approved quality.

Design Example 2 Cont'

FIRE RATED PERIOD : 2 HOURS
 PRODUCT USED : CP 670 FIRE SAFETY COATING
 CP 606 FLEXIBLE FIRESTOP SEALANT

British Standard
BS 476-20



- 1. CONCRETE FLOOR OR WALL ASSEMBLY
- ~~A. CONCRETE WALL OR FIRE RATED BLOCKWALL (MIN. 100mm THICK).~~
- B. CONCRETE FLOOR (MIN. 150mm THICK).
- 2. METAL CABLE TRAY(S).
- 3. ELECTRIC CABLE(S).
- 4. DOUBLE LAYERED (50mm THK EACH) MINERAL WOOL BOARD (MIN. 160kg/m³ DENSITY)
- 5. MINIMUM 0.7mm (DRY) THICK **HILTI CP670 FIRE SAFETY COATING** APPLIED ON BOTH SIDES OF THE MINERAL WOOL BOARD.
- 6. MINIMUM 150mm COAT BACK OF **HILTI CP670 FIRE SAFETY COATING** APPLIED ON BOTH SIDES OF THE CABLE AND CABLE TRAY PENETRATION.


CP643 Firestop Jacket

Features:

- For CP643: up to 2-hr-FRP
- For CP643S (stainless Steel casing): up to 2-hr & 4-hr Fire rating

Applications:

- UPVC Water Pipes from external dia. 32mm to 100mm



■ **Example for Intumescence with pressure**

What is the power of a 10" (250mm) collar ?



Material Technology Take 5




**Abt. 31 t
or 4 elephants**




**Inlay
surface:
9 x 35,4 inch
23 x 90 cm**

CP648 Intumescent Pipe Wraps



CP 648-E



Site Installation



CP651 Firestop Cushion

Install or re-install...
Simply convenient.

- max opening size 1mx1.5m



CP672 Firestop Joint Spray



2005 Madrid Windsor Tower



The One-Stop CP 653 Speed Sleeve




Trades / Applications : Hilti CP 653 Speed Sleeve for High Traffic Cable Penetrations



Pre-installed cable management device



2"- and 4"-diameter solutions for high traffic cable penetrations



Wall and floor applications

I&G, Telecom and Electrical

Installation – MATH

1. Making the hole



2. Attaching to the wall or floor



3. Threading cables through



4. Hindering smoke, gases & fire



Customer Value: The 4 most important sales arguments you should know

Outperform

Smoke Leakage Rating (L-rating)

- Inner fabric tube limits smoke migration from room-to-room significantly, protecting occupants and equipment.

Speed of installation

- Cylindrical profile facilitates fast installation (wall and floor) via bi-metal hole saws and core bits; “spin on” flanges promote fast product fixation – no screws needed!



Outlast

User friendly cable re-penetration

- Frequent re-penetration by easy opening and closing the device: depress the red tabs from one side and twist the inner housing, no special tools required!

Ageing tested


- Built to work during the lifetime of the building

System : Project Securing, Gateway* Product that initiates the Application Chain and Introduces 4 Different Hilti Lines



*** specified product which guarantees early project entree**

Summary / Index: CP 653 Firestop Sleeve – The easy way of cable management



Trades / Customers

- I&G (hospitals), Telecom and Electrical

Applications

- One-stop firestop solution for cable penetrations in wall and floor applications
- Integrated and superior smoke seal
- Easy solution for frequent re-penetration

Competition

- STI
- 3M

Customer Need		Customer Value / Sales Argument	Product Features
Outperform	High productivity	<ul style="list-style-type: none"> ▪ Fast install translates to lower total installed cost ▪ Up to 100% cable load 	<ul style="list-style-type: none"> ▪ Round profile and spin-on flanges promote fast installation ▪ Device may be easy opened and closed from one side
	Air leakage	<ul style="list-style-type: none"> ▪ Whether empty or 100% visual fill, CP 653 boasts very low L-rating values 	<ul style="list-style-type: none"> ▪ Constrictive smoke seal limits smoke migration by reducing (1) the annular space between cable bundles and inside of the CP 653; and (2) the interstitial spaces between cables
Outlast	Product longevity & performance	<ul style="list-style-type: none"> ▪ Designed for frequent re-penetrations and long-term service 	<ul style="list-style-type: none"> ▪ UL 1479 testing; 30 years age testing for wrap strip ▪ UL L-rating: 1 cfm / ft2 for empty or single cable penetrations; 7 cfm / ft2 may be achieved for cable bundles ▪ Further testing on additional attributes in process
	Service	<ul style="list-style-type: none"> ▪ Broad UL listing range ▪ Technical support / EJ service ▪ Breadth of additional product offerings 	<ul style="list-style-type: none"> ▪ UL tested and approved ▪ FM approved ▪ Hilti on-site support

CP617 Firestop Putty Pad

Features:

- Quick & Simple to install
- Pad can be moulded by hand to fit any size of outlet box
- Proven to re-instate the full acoustic performance of a $R_w = 65\text{dB}$ drywall




Never build another baffle box



CP617 Firestop Putty Pad




Application Procedure




1. Remove label from one side of CP 617




2. Adhere CP 617 to application



3. Reshape CP 617 fit around box



4. Press CP 617 to all sides of application



5. Remove other side of label

Additional Tests

Case 4: Fire Sealing in Complicated Openings...

Weak Points in Fire Compartment



- **Fire, smoke and acoustic barrier failed**
- **Location difficult to reach**



Water
resistance



Sound
insulation




Smoke- and
gas-tightness

30
years

Ageing
resistance

Acoustics: Sound Insulation Testing



Sound magnitude / source room

Sound magnitude / receiving room

→ Measurements are taken to determine country specific noise reduction values


Water tightness of firestop systems minimizes consequential damage

Challenges for floor openings:

- Water leakage w/o fire impact e.g. broken pipe
- Water leakage as results of fire
 - ↔ fire insurance impact
 - ➔ Water running out of compartment

Target for floor openings:

- Make sure that water stays in the compartment
- ➔ Minimize consequential losses
- ➔ **UL test for firestop products: UL 1479 / W-Rating**






Water tightness – testing



Conditions for **UL1479/W-rating**

Class 1 – commercial construction

- 1 m water column ❶
- Water (colored) ❷
- Test specimen ❸
- 72 hours (daily check of leakage)
- No leakage
- Fire test afterward



Gas-/ water-/ fire-barrier in one product



Gas

Methane / Nitrogen / CO2

IBeWa Certificate
(DIN / ASTM / GB – Doc. L)

Water

1m water column

Internal Report
(UL1479 W-rating)


Fire

2-hour FRP

BRE Test Report
(BS476 pt-20)

CP620 Firestop Foam as the ONLY perfect solution

Even more ... Blast Protection



Fraunhofer
Institut
Kurzzeitdynamik
Ernst-Mach-Institut

Director
Prof. Dr. rer. nat. Klaus Thoma
Am Klingelberg 1
79108 Erfringen-Kirchen

Test Report Summary of
Test Report No. 01-2001-AB-5 (January 2001)

in compliance with the European Standard specification
of Ref. No. prEN13123-1:1998 E and prEN13124-1:1998 E

Windows, doors and shutters - Explosion resistance
- Requirements and classification, Part 1: Shock Tube
- Test method, Part 1: Shock Tube

The Applicant: Hilti Entwicklung Elektrowerkzeuge GmbH
Bereich Befestigungstechnik
Hiltistrasse 6
86916 Kaufring

The reference, manufacturer's trade mark type of tested product and assembling :

Test specimen:	Modul „CP 620“-3	which was previously tested in the EPR3 classification of explosion pressure resistance and subsequently, in an unmodified test set-up, successful in EPR 4
----------------	------------------	---

Prior to being assembled, Module „CP 620“ has the dimensions 585 ± 10 mm x 785 ± 10 mm. The soffit of the structural component, having a wall thickness of 200 mm and built of foam concrete, has an opening of 360 ± 10 mm x 520 ± 10 mm in which, according to DIN 4102, part 9, firestop system „CP 620“ together with the cable lines and cable types can be found. The holding construction system M, developed by Hilti, for the low cable lines is fixed to the component soffit. These lateral mounting rails and the lower and upper structural component soffits serve as bearing in the test specimen frame at the rear face. By means of two additionally cross struts the module was attached to the test specimen frame at the attack face (load side). All cables lie on galvanized steel trays. Plastic cable ties serve to fix the cables to the trays, which are attached to the holding profiles with the help of iron taping wire. When assembled, the cables and cable lines stick out of the module on both sides at about 500 mm. The upper cable line adorns the soffit on one side, the lower one is positioned in the center of the soffit. The installation was carried out following the product data sheets provided by Hilti. The side exposed to the load was chosen at random on site by the examiner.

The test refers to the loading of a partial area of 470 ± 10 mm x 610 ± 10 mm, which was tested for punching and composite effect of the fire protection material „CP 620“ as termination for the cable types according to DIN 4102, part 9, as well as composite effect between fire protection material „CP 620“ and foam concrete. This test gives no information concerning the ability of the surrounding wall or building structure to resist the direct or transmitted forces.


Observation:

No perforation or visual opening through the test specimen is evident after the test, also no visual opening between the test specimen frame and the test specimen and **no splinters (NS)** ejected from the rear face (protected side). There was some formation of cracks at the foam concrete on both sides, but **no further visual damage** has been seen. The test criteria from Ref. prEN13123-1:1998 were fulfilled in this case.


Classification of the level of Explosion-Pressure-Resistance:


Classification EPR4 (NS)

Erfringen-Kirchen, 31.01.2001



Dr. Ch. Mayrhofer
(Head of Division – Protective Structures)





Dipl.-Ing. (FH) C. Kranzer
(Staff Scientist – Protective Structures)

Test Report: 01-2001-AB-5
Carried by: EMI in Germany

Test:
a very sudden rise in pressure of 0.5 to 2 bar,
which corresponds to a pressure of 50 ~ 200 kPa

Result:
class EPR4
in accordance with EN 13123 and EN 13124

Additional information – provide upon request

Submission and Approval


No matter which countries, firestop submission approval are based on the following 3 requirement:



Product

- Local + intl' approval
- Validity of product
- Job reference

+



Details

- Joint width
- Opening size
- Base material
- Penetration items

+



Quality Control

- Factory audit
- Training
- Workmanship
- Site inspection

For “Quality Control”, what Hilti can offer...

Application details (trade specific)

TOP OF WALL JOINT APPLICATION DETAIL (1 OF 3) British Standard
BS 476-20

FIRE RATED PERIOD: 4 HOURS
PRODUCT USED: CP606 FIRESTOP SEALANT

CROSS-SECTIONAL VIEW

- CONCRETE FLOOR ASSEMBLY (4-HR F.R.P.).
- CONCRETE WALL OR FIRE-RATED BLOCK WALL (MIN. 150mm THK) (4-HR F.R.P.).
- MIN. 100kg/m³ DENSITY MINERAL WOOL FULLY FILLED ACROSS AS BACKING. SEE NOTES NO. 2 BELOW FOR DIFFERENT BACKING MATERIAL.
- (JOINT WIDTH ≤ 15mm) MIN. 6mm DEPTH HILTI CP606 FLEXIBLE FIRESTOP SEALANT, FLUSH WITH BOTH SIDES OF THE WALL SURFACE.
(JOINT WIDTH ≤ 30mm) MIN. 15mm DEPTH HILTI CP606 FLEXIBLE FIRESTOP SEALANT, FLUSH WITH BOTH SIDES OF THE WALL SURFACE.

NOTES:

- MAXIMUM JOINT WIDTH = 30mm.
- INTEGRITY & INSULATION PERFORMANCE SUMMARIZED AS BELOW:

JOINT WIDTH	SEALANT DEPTH	BACKING MATERIAL	INTEGRITY	INSULATION
≤ 15mm	6mm	MINERAL WOOL	4-HR	4-HR
≤ 30mm	15mm	MINERAL WOOL	4-HR	3-HR
≤ 15mm	6mm	CF 125-50 FOAM	2-HR	1-HR
≤ 30mm	15mm	CF 125-50 FOAM	4-HR	2-HR
≤ 15mm	6mm	PE ROD	2-HR	1-HR
≤ 30mm	15mm	PE ROD	4-HR	2-HR

ALL CONFIGURATIONS SHOWN, MUST BE SUBMITTED AND APPROVED BY THE SPECIFYING ARCHITECTS OR ENGINEERS FOR THE PROJECT. FOR ANY DETAILS BEYOND THE SCOPE AS ABOVE, PLEASE CONTACT HILTI ENGINEERING SERVICE FOR ADVICES.
REFERENCE TEST REPORTS: WARRES No. 69754/C & WIRC No. 141323
WF No. 168400

HILTI Hilti Firestop Systems	HILTI (HONG KONG) LTD. Designed by Michael Leung	Sheet 1 OF 1 Scale NIL Date 9th JAN, 2009	Drawing No. TW-09001
--	--	---	-------------------------

Saving Lives through Innovation and Education

Copy Right Reserved By Hilti Corporation

Manufacturer Cert (+ Delivery note tracking)

HILTI
Certificate No. 008

Manufacturer Certificate

This is to certify HILTI (HONG KONG) LTD. has supplied

Product: CP606 Flexible Firestop Sealant

A long-term functionality for 25-30 years under room condition and fire resistance period is up to 4 hrs

Project: CEPAGE – 23 Wing Fung Street, Wan Chai
(Location: Service Penetration for Fridge & Red Wine Storage Cabinet)

Completion: 12 Dec 2008

In accordance with Building Regulation

BS476 : Part 20, 1987

Test Report No.: Warres No. 69754C

To: Wal Man Engineering Company

Signature _____ Date 2 Jan 2009

Site demonstration and training



Open Discussion

ricky.tsang@hilti.com